

DIKGATLONG LOCAL MUNICIPALITY



ADVERTISEMENT: FORMAL WRITTEN PRICE QUOTATION FOR SEVEN DAYS NOTICE

BID NO: RFQ17/2023/24

Dikgatlong Municipality hereby invites suitably prospective service providers to quote for supply and delivery of electrical material in Barkly West. **Sealed** Price quotations clearly marked “**RFQ17/2023/24 SUPPLY AND DELIVERY OF ELECTRICAL MATERIALS**” clearly endorsed on the envelope” must be submitted to the Dikgatlong Local Municipality, 33 Campbell Street, Barkly West, 8375. Bids **must** reach the municipality before **12h00 on Thursday the 1st of February 2024**.

BACKGROUND AND SPECIFICATIONS/ SCOPE OF WORK

Item no	Qty	Description
1	1	Portable Working Earth Kit (1-33KV) which includes <ul style="list-style-type: none">• 4 x 2m Phase leads of 16mm² flexible copper insulated with snap on clamps both sides.• 2 x 10m Phase to cluster bar leads of 16mm² flexible copper insulated with snap on clamps one side and earth clamps on the other side.• 1 x 4m Cluster bar to earth rod lead of 16mm² flexible copper insulated with earth clamps on both sides.• 1 x Cluster bar• 1 x Cluster head• 1 x Heavy duty carry bag
2	30	AC Circuit Breaker 63A. <ul style="list-style-type: none">• Complies with AC protection IEC 60947-2 and switch disconnect IEC 60947-3• 1 Pole• Top and bottom connection• Mounting: din rail/ mini rail (26mm)• Insulated voltage: 240/415 V• kA Rating: 6KA• Curve 2• QF range dual mount high ratings 26 MM hydraulic-magnetic

3	30	<p>AC Circuit Breaker 80A.</p> <ul style="list-style-type: none"> • Complies with AC protection IEC 60947-2 and switch disconnect IEC 60947-3 • 1 Pole • Top and bottom connection • Mounting: din rail/ mini rail (26mm) • Insulated voltage: 240/415 V • kA Rating: 6KA • Curve 2 • QF range dual mount high ratings 26 MM hydraulic-magnetic
4	500m	<ul style="list-style-type: none"> • ABC 70mm square Ariel Bundle Conductor, with bare neutral + street light conductor • Complies with SANS 1507 -6
5	50	<ul style="list-style-type: none"> • Suspension Clamp bare neutral 50-70mm
6	25	<ul style="list-style-type: none"> • ABC Strain clamp bare neutral
7	500m	<ul style="list-style-type: none"> • 10mm squared SNE + solid pilot Airdac • Complies with SANS 1507 -6
8	25	<ul style="list-style-type: none"> • Pigtail bolt M16x380mm
9	6	<ul style="list-style-type: none"> • Dropout Fuse silicone cut-out carrier 11KV
10	30	<ul style="list-style-type: none"> • Fuse links, solid button 15A/ 11KV
11	15	<ul style="list-style-type: none"> • Fuse link, solid button 65A/ 11KV
12	30	<ul style="list-style-type: none"> • Fuse link, solid button 25A/ 11 KV
13	50	<ul style="list-style-type: none"> • Insulation Piercing Clamp 25- 95mm
14	50	<ul style="list-style-type: none"> • PG clamps 2 bolts 4-15mm aluminium
15	30	<ul style="list-style-type: none"> • 70x16 aluminium lugs
16	30	<ul style="list-style-type: none"> • 70 mm ferrules
17	100	<ul style="list-style-type: none"> • 16 mm ferrules
18	50	<ul style="list-style-type: none"> • 35mm ferrules
19	30	<ul style="list-style-type: none"> • 25 mm ferrules
20	10	<ul style="list-style-type: none"> • Red insulation tape
21	10	<ul style="list-style-type: none"> • Black insulation tape
22	10	<ul style="list-style-type: none"> • Yellow insulation tape
23	10	<ul style="list-style-type: none"> • Blue insulation tape
24	2	<ul style="list-style-type: none"> • Wire grip Come along
25	1	<ul style="list-style-type: none"> • 1500 kg lever hoist ratchet

26	2	<p>Three Phase Circuit Breaker</p> <ul style="list-style-type: none"> • 300A rated current • 25KA rating • 415V rated service voltage AC • Frequency 50HZ • Thermal magnetic trip unit • Flexible connection Collar terminals, front and rear connections, straight connections, spreaders, plug in • Earth leakage protection • Rated insulation voltage 690V • Storage temperature -25°C to +70°C • Operating temperature -5°C to +60°C
27	1	<p>Three Phase Circuit Breaker</p> <ul style="list-style-type: none"> • 500A rated current • 35KA rating • 415V rated service voltage AC • Frequency 50HZ • Thermal magnetic trip unit • Flexible connection Collar terminals, front and rear connections, straight connections, spreaders, plug in • Earth leakage protection • Rated insulation voltage 690V • Storage temperature -25°C to +70°C • Operating temperature -5°C to +60°C
28	1	<p>Insulating Stick for Medium Voltage Overhead Network (4- 36 KV) with a complete range of accessories namely; operating hooks, voltage detector, trees trimmer.</p> <ul style="list-style-type: none"> • Operation of disconnect switches • Use with voltage detectors • Application of LV/MV earthing devices • Maintenance work (Tree trimming, Conductor cleaning ...) • 10.60m length when extended. • Complies with IEC 62193 • Complies with IEC 60855-1 • Complies with ASTM F 711 • Complies with ASTM F 1826
29	30	<p>Waterproof Pole mounting enclosure</p> <ul style="list-style-type: none"> • 300X200MM 5way enclosure
30	15	2.5m, 140mm power line wooden cross arm
31	15	450mm threads rods
32	15	1.5m copper earth spike rods
33	200m	16 mm squared Insulated copper wire
34	8	Galvanised pipe 20mm, 6m long
35	1	<p>Cordless Rotary Hammer Drill Kit</p> <ul style="list-style-type: none"> • Rating: industrial • Batteries included 20V-7.5AH • Battery type: lithium ion • LED battery power indicator

		<ul style="list-style-type: none"> • Motor type: brushless • Impact energy: 2.6 Joules or above • No load speed: 1550 rpm or above • Super-fast charger included • Carry case included
--	--	---

NB: If the bidder does not quote for all the items, then they will be automatically disqualified.

Items must be SAB approved

1. Late, emailed, faxed, incomplete quotes will not be considered.

2. All quotes will be adjudicated and awarded in terms of the Dikgatlong Local Municipality Procurement and Supply Chain Management Policy, the Preferential Procurement Policy Framework Act, Act No. 5 of 2000 and the regulations promulgated under this Act. This bid is subject to the General Conditions of Contract and, if applicable, any other Special Condition of Contract.

3. Quotes must be valid for a period of 30 days

4. Suppliers must submit their quotes with the following documentation and or information:

4.1 A valid original Tax Clearance certificate or a valid tax pin.

4.2 A certificate certifying that the bidder has no undisputed commitments for Municipal services towards a municipality or service provider i.r.o. payments which are overdue more than 90 days; if the bidder is the lessee a valid lease agreement together with the municipal account of the landlord; or a letter from tribal authority if the service provider operates in rural area.

4.3 Certified evidence of B-B.B.E.E. contributor status by SANAS, IRBA or SANAS accredited agencies or valid affidavit order to claim HDI points.

4.4. MBD 4, 6.1, 8 and 9 must be fully completed and submitted together with a quotation.

4.5. Bidders must be registered on the Central Supplier Data Base.

4.6. The tender will be evaluated in terms of the 80/20 preference points system of which 80 points will be for price and 20 points for specific goals (HDI and Locality) as illustrated below.

SPECIFIC GOALS			
B-BBEE (10)		Locality (10)	
B-BBEE Status Level of Contributor	Number of Points for HDI	Locality	Number of Points for Locality
1	10	Within the boundaries of Dikgatlong Local Municipality	10
2	9		

SPECIFIC GOALS			
B-BBEE (10)		Locality (10)	
B-BBEE Status Level of Contributor	Number of Points for HDI	Locality	Number of Points for Locality
3	7	Within the boundaries of Frances Baard District Municipality	8
4	6		
5	4		
6	3	Within the boundaries of Northern Cape	6
7	2		
8	1	Within the boundaries of South Africa	4

5. The Municipality does not bind itself to accept the lowest or any bid and reserves the right to accept the whole or only part of a bid if (a) the bid amounts received are too high; (b) the bids do not comply with the specific bid goals; or (c) objective criteria exist which justify or necessitate the non-acceptance of any bids.
6. Address and the vat number (4450111283) of the municipality must appear on the quote.
7. Failure to meet the above requirements or submission of documents, except for submission of BBBEE certificate or Valid sworn affidavit will lead to disqualification of the quotation.

Enquiries must be directed to: SCM Office at Tel no: (053) 531 6500.

Ms B Tsinyane
Acting Municipal Manager

Notice date: 24/01/2024