

DIKGATLONG LOCAL MUNICIPALITY



ADVERTISEMENT FORMAL WRITTEN PRICE QUOTATION FOR SEVEN DAYS NOTICE

BID NO: RFQ12/2025/26

Dikgatlong Municipality hereby invites suitably prospective service providers to quote for **SUPPLY, DELIVERY AND OFFLOADING OF LED STREET LIGHTING FITTINGS** clearly endorsed "RFQ12/2025/26 SUPPLY, DELIVERY AND OFFLOADING OF LED STREET LIGHTING FITTINGS" on the envelope must be submitted **on the tender box** situated at the reception area of Dikgatlong Local Municipality, 33 Campbell Street, Barkly West, 8375.

Bids **must** reach the municipality before **14h30 on Thursday the 27th of November 2025**.

BACKGROUND AND SPECIFICATIONS/ SCOPE OF WORK PURPOSE

PURPOSE

The purpose of this memorandum is to request the purchase of LED street light fittings to replace the existing faulty mercury vapour lamps currently installed at various locations.

BACKGROUND

During recent maintenance inspections, it was observed that several mercury vapour street lights have become faulty due to lamp failures and worn-out fittings. These lamps have reached the end of their operational life span and no longer provide adequate illumination. Mercury vapour lamps are also less energy efficient and not environmentally friendly compared to modern LED technology. LED fittings offer several advantages, including:

Lower energy consumption and operational costs.

Longer service life and reduced maintenance requirements.

Improved lighting quality and brightness.

SPECIFICATIONS

Qty	Type	Nominal flux (lm)	Luminaire output flux (lm)	Typical Output (W)
60	Luminaire fitted with 400W HPS lamp	31,943 lm	28,749 lm	195W

13	Luminaire fitted 125W Mercury Vapour lamps.	Check descriptions below.
----	---	---------------------------

38 Watt LED

Luminaire The luminaire must consist of 3 compartments viz: LED Engine, Power supply, and Spigot compartments. This allows for the easy installation of the LED engine by means of a hinging action onto a spigot base casting, with incorporated leveling device. It must be secured by stainless steel latches and an access screw. The LED engine must consist of the LED light source and the power supply unit must easily be replaceable when faulty. Both compartments must be rated at IP 66 according to **SANS 60598-2-3**.

The luminaire must be fitted with electronic temperature monitoring which prevents overheating of LEDs and power supply, positioned directly next to the LEDs (ThermiX®). The power supply must automatically disengage when the luminaire is opened. The luminaire housing must be manufactured of marine grade aluminium (**EN 1706 AC-44300**).

The Protector must be manufactured from **High-impact clear glass IK 09 according to SANS 62262**. Coating: Unpainted aluminium.

Luminaire spigot entries shall comply with **SANS 1088** - Side entry - $\varnothing 42\text{mm}$ x 125mm long. The luminaire must be fitted with **10kV/10kA Surge protection**. The luminaire must be able to operate at a nominal line voltage of 230V and a mains tolerance voltage between **198-264V - 50Hz**. The Lifetime residual flux @ Tq **25°C In accordance with LM-80 – TM-21 must be 90% at 100 000 hours. The light colour must be Neutral white (4000K, CRI ≥ 70) with 5663 lumen.**

1. Late, emailed, faxed, incomplete quotes will not be considered.
2. All quotes will be adjudicated and awarded in terms of the Dikgatlong Local Municipality Procurement and Supply Chain Management Policy, the Preferential Procurement Policy Framework Act, Act No. 5 of 2000 and the regulations promulgated under this Act. This bid is

subject to the General Conditions of Contract and, if applicable, any other Special Condition of Contract.

3. Quotes must be valid for a period of 30 days

4. Suppliers must submit their quotes with the following documentation and or information:

4.1 A valid original Tax Clearance certificate or a valid tax pin.

4.2 **A certificate certifying that the bidder has no undisputed commitments for Municipal services towards a municipality or service provider i.r.o. payments which are overdue more than 90 days; if the bidder is the lessee a valid lease agreement together with the municipal account of the landlord; or a letter from tribal authority if the service provider operates in rural area.**

4.3 MBD 4, 6.1, 8 and 9 must be fully completed and submitted together with a quotation.

4.4 Bidders must be registered on the Central Supplier Data Base.

4.5 The tender will be evaluated in terms of the 80/20 preference points system of which 80 points will be for price and 20 points for specific goals (Locality and HDI) as illustrated below

SPECIFIC GOALS		
Historical disadvantaged Individuals (10 max points)	Locality (10 max points)	
Number of Points for HDI	Locality	Number of Points for Locality
10 points will be awarded to the service provider with more than 50% ownership of the business by HDI.	Within the boundaries of Dikgatlong Local Municipality	10
	Within the boundaries of Frances Baard District Municipality	8
	Within the boundaries of Northern Cape	6
	Within the boundaries of South Africa	4

5. Address and the vat number (4450111283) of the municipality must appear on the quote.
6. The payment will only be done once the service provider has completed the project, therefore not partial payments will be done.
7. Failure to meet the above requirements or submission of documents will lead to disqualification of the bid.

The Municipality does not bind itself to accept the lowest or any bid and reserves the right to accept the whole or only part of a bid if (a) the bid amounts received are too high; (b) the bids do not comply with the specific bid goals; or (c) objective criteria exist which justify or necessitate the non-acceptance of any bids.

Enquiries must be directed to: SCM Office at Tel no: (053) 531 6500 or email m.gawuzela@dikgatlong.gov.za

Ms. B Tsinyane
Municipal Manager

Notice date: 19/11/2025

